Combination
PC-400-ES with NR-12-TRS-2 and EUROTRONIK-10

Water level control
NR-12-TRS-2

on/off

water input

0 I

water missing

filterpump

osf **NIVEAU**-control

NR-12-TRS-2

CE

temperature °C

25

20 30

15 35

10 40

off

○ heating/cooling
○ filter
○ fault
◉ reset
⚙ protection
0-8A

filtertime

automatic

off/0 ——— manual

osf **POOL**control

PC-400-ES

CE

osf

EUROTRONIK-10

16:42
Backwash

| L1 | N | ⊕ | U1 | N | ⊕ | 8 | 5 | 6 | 7 | 4 | 14 | 13 | 12 | 11 |

mains 230V
1/N/PE

solenoid valve 230V

water level
sensor

water tank
for overflow system

| 11 | 12 | 13 | 14 | U1 | V1 | W1 | N | SK | SK | L1 | L2 | L3 | N | ⊕ | L1 | 22 | 23 | N | 20 | 21 | 30 | 31 | 2 | 3 | 4 | 5 |

motor protect contact

mains 400V
3/N/PE

filterpump
230V

heating pump
or cooling
230V

mains230V
1/N/PE

outlet
pump

N

chemical control

dosig
pump

temperature probe

| 5 | 4 | 3 | 2 | L1 | N | ⊕ | U2 | U3 | N | ⊕ | 10 | 11 |

mains 230V
1/N/PE

pressure switch

osf

actuating drive

open in oposition "backwash" and "clear wach",

closed in position filtering